



THE INFORMATION HEREON IS THE PROPERTY OF SIMPLEX, INC., AND/OR ITS SUBSIDIARIES. WITHOUT WRITTEN PERMISSION ANY COPYING, TRANSMITTAL TO OTHERS AND USE EXCEPT THAT FOR WHICH IT IS LOANED IS PROHIBITED.

© 2007 SIMPLEX, INC. ALL RIGHTS RESERVED



LOUVERS OPEN

A

COOLING FAILURE

R

OVER TEMPERATURE

R

FAN FAILURE

R

ACCESS DOOR(S) AJAR

R

LOUVERS CLOSED

A

REMOTE CONTROL ACTIVE

G

CONTROL POWER ON

G

NORMAL OPERATION

G

LOAD DUMP BYPASSED

A

FAN/CONTROL POWER

OFF ON

MODE SELECT

REMOTE LOCAL

LOAD DUMP BYPASS

ENABLED BYPASS

RESISTIVE LOAD STEP CONTROLS

RESISTIVE MASTER LOAD

ON OFF

4.1KW 5KW

ON OFF

8.5KW 10KW

ON OFF

8.5KW 10KW

ON OFF

21KW 25KW

ON OFF

480V 600V

42KW 50KW

ON OFF

85KW 100KW

ON OFF

85KW 100KW

ON OFF

170KW 200KW

ON OFF

425KW 500KW

ON OFF

480V 600V

850KW 1000KW

ON OFF

850KW 1000KW

ON OFF

LOW VOLTAGE 480VAC,3Ø,60HZ

HIGH VOLTAGE 600VAC,3Ø,60HZ

FAN/CONTROL POWER VOLTAGE SELECTOR

340

SIMPLX

SPRINGFIELD, ILLINOIS

SCALE:	APPROVED BY :	DRAWN BY : JPC
DATE : 3/23/07		REVISED:

RESISTIVE LOAD BANK	SATURN-3000 DV
2560KW/3000KW,480V/600V,3Ø,60HZ	LOCAL PANEL

W.O. #63798-07-43/2	DRAWING NUMBER 47BD164478
---------------------	---------------------------