



THE INFORMATION HEREON IS THE PROPERTY OF SIMPLEX, INC., AND/OR ITS SUBSIDIARIES. WITHOUT WRITTEN PERMISSION ANY COPYING, TRANSMITTAL TO OTHERS AND USE EXCEPT THAT FOR WHICH IT IS LOANED IS PROHIBITED.

© 2007 SIMPLEX, INC. ALL RIGHTS RESERVED



LOUVERS OPEN

A

COOLING FAILURE

R

OVER TEMPERATURE

R

FAN FAILURE

R

ACCESS DOOR(S) AJAR

R

LOUVERS CLOSED

A

REMOTE CONTROL ACTIVE

G

CONTROL POWER ON

G

NORMAL OPERATION

G

LOAD DUMP BYPASSED

A

FAN/CONTROL POWER

OFF ON

MODE SELECT

REMOTE LOCAL

LOAD DUMP BYPASS

ENABLED BYPASS

RESISTIVE LOAD STEP CONTROLS

RESISTIVE MASTER LOAD

OFF ON

4.1KW 5KW

OFF ON

8.5KW 10KW

OFF ON

8.5KW 10KW

OFF ON

21KW 25KW

OFF ON

480V 600V

42KW 50KW

OFF ON

88KW 100KW

OFF ON

88KW 100KW

OFF ON

170KW 200KW

OFF ON

425KW 500KW

OFF ON

480V 600V

850KW 1000KW

OFF ON

850KW 1000KW

OFF ON

LOW VOLTAGE 480VAC,3Ø,60HZ

HIGH VOLTAGE 600VAC,3Ø,60HZ

FAN/CONTROL POWER VOLTAGE SELECTOR

	REVISED NAMEPLATES	DRAWN BY : AZM
		DATE : 3/29/07
SCALE:	APPROVED BY :	DRAWN BY : JPC
DATE : 3/23/07		REVISED:
RESISTIVE LOAD BANK SATURN-3000 DV		
2560KW/3000KW,480V/600V,3Ø,60HZOCAL PANEL		
W.O. #63798-07-43/2		DRAWING NUMBER
		47BD164478A