



SEE DRAWINGS
47B164461
47B164462
47B164463
47B164467
47B164468
FOR OTHER
CONNECTIONS

- L1 LOUVERS OPEN
- L2 COOLING FAILURE
- L3 OVER TEMPERATURE
- L4 FAN FAILURE
- L5 LOAD DUMP BYPASSED
- L6 LOUVERS CLOSED
- L7 REMOTE CONTROL ACTIVE
- L8 CONTROL POWER ON
- L9 NORMAL OPERATION
- L10 OVER VOLTAGE

THE INFORMATION HEREON IS THE PROPERTY OF SIMPLEX, INC., AND/OR ITS SUBSIDIARIES. WITHOUT WRITTEN PERMISSION ANY COPYING, TRANSMITTAL TO OTHERS AND USE EXCEPT THAT FOR WHICH IT IS LOANED IS PROHIBITED.
©2007 SIMPLEX, INC. ALL RIGHTS RESERVED

NOTES:
1. UNIT MUST BE GROUNDED FOR OPERATORS SAFETY.
2. DASHED LINES INDICATE WIRING NOT SUPPLIED BY SIMPLEX.

<div><div></div><div>ADDED VSR CONTACT CORRECTED LAMP DESIGNATIONS</div></div>		REVISED BY :AZM
		DATE : 5/2/07
<div><div></div><div>MODIFIED LOUVER CONTROL, ADDED ALARM HORN</div></div>		REVISED BY :AZM
		DATE : 4/23/07
<div><div></div><div>ADDED LS1-4 & REVISED WIRING OF LOR1-2, LCR1</div></div>		REVISED BY :CMC
		DATE : 04/18/07
<div><div><div><div></div><div>SIMPLX®</div></div><div>SPRINGFIELD, ILLINOIS</div></div></div>		
SCALE :	APPROVED BY :	DRAWN BY : JPC
DATE : 3/22/07		REVISED :
RESISTIVE/INDUCTIVE LOAD BANK SATURN 3000 DV 2550KW/3000KW,480V/600V,3ø,60HzC CONTROL SECT 4		
W.O.# 63798-07-43/2		DRAWING NUMBER 47B164464C