



LOAD BANK WIRING COLOR CODED AS FOLLOWS:
 ALL AC CONTROL WIRE JUMPERS:
 LINE SIDE, "A" SIDE OF COIL - RED ("R")
 COMMON (GROUND OR NEUTRAL), "B" SIDE OF COIL - BLUE ("B")
 ALL AC POWER WIRING:
 A PHASE, LINE 1 - BLACK ("BK")
 B PHASE, LINE 2 - RED ("R")
 C PHASE, LINE 3 - BLUE ("B")
 ALL DC CONTROL WIRING:
 POSITIVE - RED WITH A WHITE STRIPE ("RW")
 NEGATIVE - BLACK WITH A WHITE STRIPE ("BKW")
 ALL DC POWER WIRING:
 POSITIVE - RED ("R")
 NEGATIVE - BLACK ("BK")
 ALL WIRES ATTACHED TO LOAD BANK GROUND - GREEN ("G")
 ALL LOAD JUMPERS AND STRAPPING - WHITE ("W")

NOTE:
 1. ALL WIRING #14 AWG PLASTIC WIRE
 UNLESS OTHERWISE SPECIFIED

THE INFORMATION HEREON IS THE PROPERTY OF SIMPLEX, INC.,
 AND/OR ITS SUBSIDIARIES. WITHOUT WRITTEN PERMISSION ANY
 COPYING, TRANSMITTAL TO OTHERS AND USE EXCEPT THAT FOR
 WHICH IT IS LOANED IS PROHIBITED.

DISK S/N: 6099		
D	CHANGED 7C35484C TO 7B35484D CHANGED 7C28040 TO 7A28040A CHANGED 7D28043 TO 7B30506A	CJG .5 2/14/92
C	REMOVED OLR1 & OLR2 CONTACTS	RLL 2 12/26/90
B	ADDED EXTS IN PLACE OF TS2 AND CHANGED NUMBERS ON S2	DY 2 6/8/90
A	REDRAWN	SAW 2 10/20/87
SIMPLX ® SPRINGFIELD, ILLINOIS		
SCALE : ~	APPROVED BY :	DRAWN BY : DY
DATE : 9/29/86		REVISED : 1
CONTROL & FAILURE WIRING DIAGRAM Q-500		
STD.		DRAWING NUMBER 7B35484D