

LOAD BANK WIRING COLOR CODED AS FOLLOWS:
ALL AC CONTROL WIRE JUMPERS:
LINE SIDE, 'A' SIDE OF COIL - RED ('R')
COMMON (GROUND OR NEUTRAL), 'B' SIDE OF COIL - BLUE ('B')
ALL AC POWER WIRING:
A PHASE, LINE 1 - BLACK ('BK')
B PHASE, LINE 2 - RED ('R')
C PHASE, LINE 3 - BLUE ('B')
ALL DC CONTROL WIRING:
POSITIVE - RED WITH A WHITE STRIPE ('RW')
NEGATIVE - BLACK WITH A WHITE STRIPE ('BKW')
ALL DC POWER WIRING:
POSITIVE - RED ('R')
NEGATIVE - BLACK ('BK')
ALL WIRES ATTACHED TO LOAD BANK GROUND - GREEN ('G')
ALL LOAD JUMPERS AND STRAPPING - WHITE ('W')

NOTE:

1. ALL WIRING #14 AWG PLASTIC WIRE UNLESS OTHERWISE SPECIFIED

DISK S/N: 6099

D	CHANGED 7C354484C TO 7B354484D CHANGED 7C26040 TO 7A26040A CHANGED 7C26043 TO 7B30506A	CJG .5 2/14/92	
C	REMOVED OLR1 & OLR2 CONTACTS	RLL 2 12/26/90	
B	ADDED EXTS IN PLACE OF TS2 AND CHANGED NUMBERS ON S2	DV 2 6/8/90	
A	REDRAWN	SAW 2 10/20/87	

SIMPLX. SPRINGFIELD, ILLINOIS

SCALE: ~ | APPROVED BY: CJG | DRAWN BY: DV
DATE: 9/29/86 | REVISED: 1

CONTROL & FAILURE WIRING DIAGRAM
0-500

STD.

DRAWING NUMBER 7B354484D

THE INFORMATION HEREON IS THE PROPERTY OF SIMPLEX, INC., AND/OR ITS SUBSIDIARIES. WITHOUT WRITTEN PERMISSION ANY COPYING, TRANSMITTAL TO OTHERS AND USE EXCEPT THAT FOR WHICH IT IS LOANED IS PROHIBITED.